

This revision replaces the runtime schedule of January 2010. Systems having only 3 bedroom homes are allotted 8 minutes pump **on** time. Systems having both 3 and 4 bedroom homes are allotted 10 minutes pump **on** time. Pumping cycle interval for all homes is 4:48:00 (hh:mm:ss).

Septic control boxes were reprogrammed with this schedule on March 11 and March 18, 2025 by PumpTech. Therefore, the schedule is on Daylight Savings Time.

RUNTIME SCHEDULES

The following is a revised runtime schedule for the dosing tanks located at the residential lots. The pump timer will be set to come on at the times indicated. No more than one pump will be on at any time. **Pump rate in the force main will not exceed 10 GPM.**

System 1

Pump Time (hh:mm:ss): On: 0:10:00 Off: 4:38:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2702 Gracie	5/3	3	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2705 Gracie	5/2	4	0:48:00	5:36:00	10:24:00	15:12:00	20:00:00
2710 Gracie	5/4	4	1:36:00	6:24:00	11:12:00	16:00:00	20:48:00
1 S Anchor Lane	1/2	4	2:24:00	7:12:00	12:00:00	16:48:00	21:36:00
2790 Mikayla (lot)	1/3	0	3:12:00	8:00:00	12:48:00	17:36:00	22:24:00
2800 Mikayla	1/4	4	4:00:00	8:48:00	13:36:00	18:24:00	23:12:00

System 2

Pump Time (hh:mm:ss): On: 0:08:00 Off: 4:40:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2858 Blue Heron	2/7	3	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2864 Blue Heron	2/8	3	0:32:00	5:20:00	10:08:00	14:56:00	19:44:00
2870 Blue Heron	2/9	3	1:04:00	5:52:00	10:40:00	15:28:00	20:16:00
2878 Blue Heron	2/10	3	1:36:00	6:24:00	11:12:00	16:00:00	20:48:00
2888 Blue Heron	2/11	3	2:08:00	6:56:00	11:44:00	16:32:00	21:20:00
2896 Blue Heron	2/12	3	2:40:00	7:28:00	12:16:00	17:04:00	21:52:00
2912 Blue Heron	2/13	3	3:12:00	8:00:00	12:48:00	17:36:00	22:24:00
2938 Blue Heron	2/14	3	3:44:00	8:32:00	13:20:00	18:08:00	22:56:00
2952 Blue Heron	2/15	3	4:16:00	9:04:00	13:52:00	18:40:00	23:28:00

This revision replaces the runtime schedule of January 2010. Systems having only 3 bedroom homes are allotted 8 minutes pump on time. Systems having both 3 and 4 bedroom homes are allotted 10 minutes pump on time. Pumping cycle interval for all homes is 4:48:00 (hh:mm:ss).

System 3

Pump Time (hh:mm:ss): On: 0:10:00 Off: 4:38:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2800 Akamai	2/1	3	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2810 Akamai	2/2	3	0:36:00	5:24:00	10:12:00	15:00:00	19:48:00
2820 Akamai	2/3	3	1:12:00	6:00:00	10:48:00	15:36:00	20:24:00
2840 Akamai	3/1	4	1:48:00	6:36:00	11:24:00	16:12:00	21:00:00
2850 Akamai (lot)	3/2	0	2:24:00	7:12:00	12:00:00	16:48:00	21:36:00
2830 Blue Heron	2/4	4	3:00:00	7:48:00	12:36:00	17:24:00	22:12:00
2840 Blue Heron	2/5	3	3:36:00	8:24:00	13:12:00	18:00:00	22:48:00
2850 Blue Heron	2/6	3	4:12:00	9:00:00	13:48:00	18:36:00	23:24:00

System 4

Pump Time (hh:mm:ss): On: 0:10:00 Off: 4:38:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2820 Mikayla	1/5	3	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2830 Mikayla	1/6	4	0:36:00	5:24:00	10:12:00	15:00:00	19:48:00
2840 Mikayla	1/7	4	1:12:00	6:00:00	10:48:00	15:36:00	20:24:00
2850 Mikayla (Park)	1/8	0	1:48:00	6:36:00	11:24:00	16:12:00	21:00:00
2860 Mikayla (lot)	1/9	0	2:24:00	7:12:00	12:00:00	16:48:00	21:36:00
2870 Mikayla	1/10	4	3:00:00	7:48:00	12:36:00	17:24:00	22:12:00
2880 Mikayla (lot)	1/11	0	3:36:00	8:24:00	13:12:00	18:00:00	22:48:00
2890 Mikayla	1/12	3	4:12:00	9:00:00	13:48:00	18:36:00	23:24:00

This revision replaces the runtime schedule of January 2010. Systems having only 3 bedroom homes are allotted 8 minutes pump **on** time. Systems having both 3 and 4 bedroom homes are allotted 10 minutes pump **on** time. Pumping cycle interval for all homes is 4:48:00 (hh:mm:ss).

System 5

Pump Time (hh:mm:ss): On: 0:08:00 Off: 4:40:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2966 Blue Heron	2/16	3	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2980 Blue Heron	2/17	3	0:48:00	5:36:00	10:24:00	15:12:00	20:00:00
2988 Blue Heron (lot)	2/18	0	1:36:00	6:24:00	11:12:00	16:00:00	20:48:00
2990 Blue Heron	2/19	3	2:24:00	7:12:00	12:00:00	16:48:00	21:36:00
2992 Blue Heron	2/20	3	3:12:00	8:00:00	12:48:00	17:36:00	22:24:00
2994 Blue Heron	2/21	3	4:00:00	8:48:00	13:36:00	18:24:00	23:12:00

System 6

Pump Time (hh:mm:ss): On: 0:10:00 Off: 4:38:00

Address	Block/Lot	BR	Dose 1	Dose 2	Dose 3	Dose 4	Dose 5
2810 Aspen Shores	4/1	4	0:00:00	4:48:00	9:36:00	14:24:00	19:12:00
2825 Aspen Shores	4/2	4	0:36:00	5:24:00	10:12:00	15:00:00	19:48:00
2835 Aspen Shores	4/3	4	1:12:00	6:00:00	10:48:00	15:36:00	20:24:00
2845 Aspen Shores	4/4	4	1:48:00	6:36:00	11:24:00	16:12:00	21:00:00
2855 Aspen Shores	4/5	4	2:24:00	7:12:00	12:00:00	16:48:00	21:36:00
2870 Akamai Way	3/3	4	3:00:00	7:48:00	12:36:00	17:24:00	22:12:00
2890 Akamai Way	3/4	4	3:36:00	8:24:00	13:12:00	18:00:00	22:48:00
Vacant placeholder*	-	0	4:12:00	9:00:00	13:48:00	18:36:00	23:24:00

*Added to allow for an even number of minutes (no seconds) for pump on and off times.

THE SYSTEM DISCHARGE RATE FOR THE DRAIN BED DOSING TANK IS APPROXIMATELY 3 TIMES THE INFLOW RATE FROM THE LOT DOSING TANKS. THIS ASSURES THAT THE AUTO SEQUENCING VALVES WILL PRESSURIZE, SEAT, DEPRESSURIZE AND ROTATE IN 81 GALLON INCREMENTS EVEN IF A LOT DOSING TANK IS ALSO RUNNING.